

# AWTA PRODUCT TESTING

Australian Wool Testing Authority Ltd - trading as AWTA Product Testing  
A.B.N 43 006 014 106

1st Floor, 191 Racecourse Road, Flemington, Victoria 3031  
P.O Box 240, North Melbourne, Victoria 3051  
Phone (03) 9371 2400

## Group Number Assessment

(In accordance with AS 5637.1-2015)

This is to confirm that the product as described below has been tested by AWTA Product Testing .


Testing was performed in accordance with AS/NZS 3837-1998 Method of test for heat and smoke release rates for materials and products using an oxygen consumption calorimeter.

As per AS 5637.1 Clause 9(n) it was valid to test this particular material / system in the cone calorimeter for the assignment of a NCC Group Number.

**Test Sponsor :** New Age Veneers Pty Ltd  
Unit 11, 22-24 Beaumont Road  
Mount Kuring-Gai NSW 2080

**Test Number :** 24-001690  
**Issue Date :** 20/05/2024  
**Print Date :** 6/06/2024

**Sponsor Product :** Clients Ref : "Navurban Diamond - FR MDF - Collingwood"  
Rigid panel  
Colour : Dark Brown  
End Use : Joinery, wall cladding, Furniture  
Nominal Composition : Embossed olefin non-PVC film with UV overlay pressed onto  
18mm EO FR MDF G2S  
Nominal Mass per Unit Area/Density : 890kg/m<sup>3</sup>  
Nominal Thickness : 18mm



70616

The message/document(s) contained in this electronic attachment is intended for the party to which it is addressed and may contain confidential information or be subject to professional privilege. It's transmission is not intended to place the contents into the public domain.

If you have received this transmission in error, it's disclosure or copying is prohibited. Please contact us by collect call so that arrangements can be made at our expense to rectify the error.

# AWTA PRODUCT TESTING

Australian Wool Testing Authority Ltd - trading as AWTA Product Testing  
A.B.N 43 006 014 106

1st Floor, 191 Racecourse Road, Flemington, Victoria 3031

P.O Box 240, North Melbourne, Victoria 3051

Phone (03) 9371 2400

## Group Number Assessment

(In accordance with AS 5637.1-2015)

This is to confirm that the product as described below has been tested by AWTA Product Testing .

Testing was performed in accordance with AS/NZS 3837-1998 Method of test for heat and smoke release rates for materials and products using an oxygen consumption calorimeter.

As per AS 5637.1 Clause 9(n) it was valid to test this particular material / system in the cone calorimeter for the assignment of a NCC Group Number.

---

<b>Test Sponsor :</b>	New Age Veneers Pty Ltd Unit 11, 22-24 Beaumont Road Mount Kuring-Gai NSW 2080	<b>Test Number :</b>	24-001690
		<b>Issue Date :</b>	20/05/2024
		<b>Print Date :</b>	6/06/2024

---

Product Group Number Classification : 3

Average Specific Extinction Area : 0.0 m<sup>2</sup>/kg



Chris Campbell  
Client Relations Manager

70616

---

The message/document(s) contained in this electronic attachment is intended for the party to which it is addressed and may contain confidential information or be subject to professional privilege. It's transmission is not intended to place the contents into the public domain.

If you have received this transmission in error, it's disclosure or copying is prohibited. Please contact us by collect call so that arrangements can be made at our expense to rectify the error.