

AWTA PRODUCT TESTING

Australian Wool Testing Authority Ltd - trading as AWTA Product Testing
A.B.N 43 006 014 106

1st Floor, 191 Racecourse Road, Flemington, Victoria 3031
P.O Box 240, North Melbourne, Victoria 3051
Phone (03) 9371 2400

Group Number Assessment

(In accordance with AS 5637.1-2015)

This is to confirm that the product as described below has been tested by AWTA Product Testing .


Testing was performed in accordance with AS/NZS 3837-1998 Method of test for heat and smoke release rates for materials and products using an oxygen consumption calorimeter.

As per AS 5637.1 Clause 9(n) it was valid to test this particular material / system in the cone calorimeter for the assignment of a NCC Group Number.

Test Sponsor : New Age Veneers Pty Ltd
Unit 11, 22-24 Beaumont Road
Mount Kuring-Gai NSW 2080

Test Number : 24-001716
Issue Date : 24/05/2024
Print Date : 6/06/2024

Sponsor Product : Clients Ref : "Shinnoki by Nav - MR MDF Desert Oak"
Rigid Panel
Colour : Beige
End Use : Joinery, Wall Cladding, Furniture
Nominal Composition : Prefinished Natural Timber veneer pressed onto 18mm EO MR MDF G25
Nominal Mass per Unit Area/Density : 730kg/m³
Nominal Thickness : 20mm



70657

The message/document(s) contained in this electronic attachment is intended for the party to which it is addressed and may contain confidential information or be subject to professional privilege. Its transmission is not intended to place the contents into the public domain.

If you have received this transmission in error, its disclosure or copying is prohibited. Please contact us by collect call so that arrangements can be made at our expense to rectify the error.

AWTA PRODUCT TESTING

Australian Wool Testing Authority Ltd - trading as AWTA Product Testing
A.B.N 43 006 014 106

1st Floor, 191 Racecourse Road, Flemington, Victoria 3031
P.O Box 240, North Melbourne, Victoria 3051
Phone (03) 9371 2400

Group Number Assessment

(In accordance with AS 5637.1-2015)

This is to confirm that the product as described below has been tested by AWTA Product Testing .

Testing was performed in accordance with AS/NZS 3837-1998 Method of test for heat and smoke release rates for materials and products using an oxygen consumption calorimeter.

As per AS 5637.1 Clause 9(n) it was valid to test this particular material / system in the cone calorimeter for the assignment of a NCC Group Number.

Test Sponsor :	New Age Veneers Pty Ltd Unit 11, 22-24 Beaumont Road Mount Kuring-Gai NSW 2080	Test Number :	24-001716
		Issue Date :	24/05/2024
		Print Date :	6/06/2024

Product Group Number Classification : 3

Average Specific Extinction Area : 9.9 m²/kg



Chris Campbell
Client Relations Manager

70657

The message/document(s) contained in this electronic attachment is intended for the party to which it is addressed and may contain confidential information or be subject to professional privilege. It's transmission is not intended to place the contents into the public domain.

If you have received this transmission in error, it's disclosure or copying is prohibited. Please contact us by collect call so that arrangements can be made at our expense to rectify the error.