

VOC Emission Test Certificate

Wednesday 06th September 2023

Supplier: New Age Veneers of Mt Kuring-gai (11/22-24 Beaumont Rd, Mount Kuring-gai, NSW, 2080, AUSTRALIA).

Product Name: Navurban Wall _ Thickness 1 mm

Date Tested: 18th August 2023 (Tested by FORAY Laboratories – NATA Accreditation 1231)

Test Method: ASTM D5116-2017 “Standard Guide for Small-Scale Environmental Chamber Determinations of Organic Emissions from Indoor Material/Products”.

Test Data (24 hrs):


Specification Green Building Council of Australia Green Star Design & As Built V1.3-13.1.1B Green Star Interiors V1.3-12.1.1B	Navurban Wall _ Thickness 1 mm
Total Volatile Organic Compound Emission Rate Limit: $\leq 0.500 \text{ mg/m}^2/\text{hr}$	Total Volatile Organic Compound Emission Rate: $0.046 \text{ mg/m}^2/\text{hr}$
Formaldehyde Emission Rate Limit: $\leq 0.100 \text{ mg/m}^2/\text{hr}$	Formaldehyde Emission Rate: $0.014 \text{ mg/m}^2/\text{hr}$



Dr. Vyt Garnys
PhD, BSc(Hons) AIMM, ARACI, ISIAQ
ACA, AIRAH, FMA
Managing Director and Principal Consultant



Dr. Tuan Duong
PhD, BE (Chemical Engineer)
Senior Consultant



Travis Hale
BSc (Biotechnology)
Senior Consultant